



Product Service

# Attestation of Conformity

No. N8A 001119 0026 Rev. 01

**Holder of Attestation:** **ZHUHAI LTECH TECHNOLOGY CO., LTD.**

15th Building, No.3, Pingdong 6th Road  
Nanping Technical Industrial Park  
519060 Zhuhai, Guangdong  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Power supplies  
(LED DRIVER)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 651402013202

**Date,** 2023-04-28

( Taylor Yao )

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**



Product Service

# Attestation of Conformity

No. N8A 001119 0026 Rev. 01

**Model(s):** SE-15-350-700-G1T; SE-15-150-500-G1T;  
SE-12-100-400-G1T; SE-12-350-700-G1T;  
SE-9-350-700-G1T; SE-9-550-900-G1T

**Brand:** LTSYS, LTECH

**LTSYS® LTECH**

## Parameters:

Rated Input Voltage: 220-240VAC  
 Rated Frequency: 50/60Hz  
 Rated Input Current: See below table for details  
 Rated Output: See below table for details  
 Protection against Electric Shock: Class II; SELV  
 Degree of Protection: IP20  
 Method of Installation: Independent  
 Type of Output: Constant current type  
 ta: -20~45°C  
 tc: 90°C

**Tested according to:** EN 61347-2-13:2014/A1:2017  
EN 61347-1:2015/A1:2021  
EN 62493:2015/A1:2022

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 001119 0026 Rev. 01

Model No.	Rated Input Current (A) Max.	Output Voltage (VDC)	I <sub>rated</sub> (mA)	DIP Switch Position			U <sub>out</sub> (VDC)	P <sub>rated</sub> (W) Max.
				1	2	3		
SE-15-350-700-G1T	0.1	9-42	350	OFF	OFF	OFF	50	15
		9-37.5	400	OFF	OFF	ON		
		9-33	450	OFF	ON	OFF		
		9-30	500	OFF	ON	ON		
		9-27	550	ON	OFF	OFF		
		9-25	600	ON	OFF	ON		
		9-23	650	ON	ON	OFF		
SE-15-150-500-G1T	0.1	9-42	150	OFF	OFF	OFF	50	15
		9-42	200	OFF	OFF	ON		
		9-42	250	OFF	ON	OFF		
		9-42	300	OFF	ON	ON		
		9-42	350	ON	OFF	OFF		
		9-37.5	400	ON	OFF	ON		
		9-33	450	ON	ON	OFF		
SE-12-100-400-G1T	0.09	9-30	500	ON	ON	ON	50	12
		9-42	100	OFF	OFF	ON		
		9-42	150	OFF	ON	OFF		
		9-42	200	OFF	ON	ON		
		9-42	250	ON	OFF	OFF		
		9-40	300	ON	OFF	ON		
SE-12-350-700-G1T	0.09	9-34	350	ON	ON	OFF	30	12
		9-30	400	ON	ON	ON		
		9-24	350	OFF	OFF	OFF		
		9-24	400	OFF	OFF	ON		
		9-24	450	OFF	ON	OFF		
		9-24	500	OFF	ON	ON		
		9-21.5	550	ON	OFF	OFF		
SE-9-350-700-G1T	0.08	9-20	600	ON	OFF	ON	22	8.4
		9-18.5	650	ON	ON	OFF		
		9-17	700	ON	ON	ON		
		2-12	350	OFF	OFF	OFF		
		2-12	400	OFF	OFF	ON		
		2-12	450	OFF	ON	OFF		
		2-12	500	OFF	ON	ON		
SE-9-550-900-G1T	0.08	2-12	550	ON	OFF	OFF	22	9
		2-12	600	ON	OFF	ON		
		2-12	650	ON	ON	OFF		
		2-12	700	ON	ON	ON		
		2-10	550	OFF	OFF	OFF		
		2-10	600	OFF	OFF	ON		
		2-10	650	OFF	ON	OFF		
SE-9-550-900-G1T	0.08	2-10	700	OFF	ON	ON	22	9
		2-10	750	ON	OFF	OFF		
		2-10	800	ON	OFF	ON		
		2-10	850	ON	ON	OFF		
		2-10	900	ON	ON	ON		
		2-10	900	ON	ON	ON		
		2-10	900	ON	ON	ON		

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®